

# Environment and Social Due Diligence Report

## (Appendices 1 to 4)

---

June 2016

### IND: Accelerating Infrastructure Investment Facility in India –Mihit Solar Power Private Limited

Prepared by

India Infrastructure Finance Company Limited for the Asian Development Bank

This report is a document of the borrower. The views expressed herein do not necessarily represent those of ADB's Board of Directors, Management, or staff, and may be preliminary in nature.

In preparing any country program or strategy, financing any project, or by making any designation of or reference to a particular territory or geographic area in this document, the Asian Development Bank does not intend to make any judgments as to the legal or other status of any territory or area.

No. J-11013/41/2006-IA.II(I)  
**Government of India**  
**Ministry of Environment & Forests**

Paryavaran Bhavan,  
C.G.O. Complex, Lodi Road,  
New Delhi-110003.  
Telefax: 24362434

Dated the 13<sup>th</sup> May, 2011


**Office Memorandum**

**Sub: Applicability of environmental clearance for Solar Photo Voltaic (PV) Power Projects – Regarding.**

A reference has been received in this Ministry seeking clarification regarding applicability of EIA Notification, 2006 in respect of Solar Photo Voltaic (PV) Power Projects. The matter has been examined.

It is clarified that the Solar PV Power Project are not covered under the ambit of EIA Notification, 2006 and no environment clearance is required for such projects under the provisions thereof.

This issues with the approval of the Competent Authority.

  
(Dr. S.K. Aggarwal)  
Director

**To**

1. All the Officers of IA Division
2. Chairpersons / Member Secretaries of all the SEIAAs/SEACs
3. Chairman, CPCB
4. Chairpersons / Member Secretaries of all SPCBs / UTPCCs

**Copy to:-**

1. PS to MEF
2. PPS to Secretary (E&F)
3. PPS to SS(JMM)
4. Advisor (NB)
5. Website, MoEF
6. Guard File

**PUNJAB POLLUTION CONTROL BOARD**  
**Nabha Road, Patiala**

No. SEE (HQ-1) /PPCB/2014/ 266


Dated: 22/9/14

**Office Order**

Earlier, the Punjab Pollution Control Board in its 149th meeting held on 20/10/2010 vide item 149.03, had decided to exempt the Solar Photovoltaic Plants less than 5 MW capacity for obtaining the consent to establish/operate from the Board under Water (Prevention & Control of Pollution) Act, 1974 and Air (Prevention & Control of Pollution) Act, 1981 for a period of five years subject to certain conditions. The office order in this regard was issued vide no. HQ-2/Solar PV/F-322/2010/08 dated 05-01-2011.

Now, the Punjab Pollution Control Board in its 165<sup>th</sup> meeting held on 10/9/2014 vide item no. 165.04 has reconsidered the matter and has decided to exempt the Solar Photovoltaic Plants irrespective of their capacity, from obtaining consent to establish (NOC)/consent to operate of the Board under Water (Prevention & Control of Pollution) Act, 1974 & Air (Prevention & Control of Pollution) Act, 1981 subject to following conditions:

- (i) That there shall not be any discharge of trade effluent from the industry into the stream, well or sewer or onto land for irrigation & it shall not cause any air pollution including noise.
- (ii) That the industry shall not discharge any toxic/hazardous waste and shall not handle any toxic/hazardous chemicals.
- (iii) The domestic effluent after treatment in septic tanks shall be used for gardening /plantation purpose inside their premises.
- (iv) At the end of the life cycle of the photovoltaic cell, batteries etc., it shall be ensured that such material shall be managed as per the provisions of the rules framed under the Environment (Protection) Act, 1986 and amended from time to time.

  
**Chairman**  
PTO.....

A copy of the above is forwarded to the following for information and necessary action please:

- 1 The Chief Environmental Engineer, Punjab Pollution Control Board, Patiala(Head Quarter) /Patiala/Jalandhar & Ludhiana.
- 2 The Senior Environmental Engineer, Punjab Pollution Control Board, Zonal Office, Patiala-I, II / Ludhiana-I, II / Jalandhar / Amritsar & Bathinda.
- 3 The Senior Environmental Engineer (HQ-I/II), Punjab Pollution Control Board, Patiala.
- 4 The Special Secretary (P&G), Punjab Pollution Control Board, Mohali.
- 5 The Senior Scientific Officer (Lab.), Punjab Pollution Control Board, Patiala.
- 6 The Environmental Engineer, Punjab Pollution Control Board, Regional Office, Patiala / Ludhiana-I/II/III/IV/ Jalandhar / Sri Amritsar / Hoshiarpur / Sri Fatehgarh Sahib / Batala / Sangrur / Bathinda / Faridkot and SAS Nagar.
- 7 The Environmental Engineer (Const./CSA/SEIAA/SEAC/Computer), Punjab Pollution Control Board, Patiala.
- 8 The Scientific Officer (Water/Air), Punjab Pollution Control Board, Patiala.
- 9 The Deputy Controller (F&A), Punjab Pollution Control Board, Patiala.
- 10 The Administrative Officer-I, II, Punjab Pollution Control Board, Head Office, Patiala.
- 11 The Law Officer (1/2), Punjab Pollution Control Board, Patiala.
- 12 The Deputy Director (P.R), Punjab Pollution Control Board, Patiala.
13. The Asstt. Personnel Officer, Punjab Pollution Control Board, Patiala.
14. PA to Chairman/ P.S. to Member Secretary, Punjab Pollution Control Board, Patiala.

  
Member Secretary

**FORM-11**  
**{See Rule 18 (1)}**  
**CERTIFICATE OF REGISTRATION**

**No. R-04/2015**


**Dated ;29-09-2015**

**GOVERNMENT OF PUNJAB**  
**OFFICE OF THE REGISTERING OFFICER**

A certificate of registration containing the following particulars is hereby granted under sub section (2) of Section 7 of the Contract Labour (Regulation & Abolition) Act 1970 and the rule made there under to **M/s Mihit solar power pvt.ltd, Vill-Mankhera, distt Mansa**

1. Nature of work : Solar Power Plant
2. Name and address of Contractors : (1) M/S Scheneider electric infrastructure limited, plot no 2B, IGL complex tower-3 Sth to 7<sup>th</sup> tower, Sec-126, noida, up,  
(2) M/S Bhandari engineering co.pvt.ltd, bhandari chowk, old bus stand bathinda.  
(3) M/S Ganges international pvt ltd 1<sup>st</sup> floor shop no 208, new grain markit, rajpura, patiala, punjab,  
(4) M/S Shreyas civil engineering, pramod apartment falt no9, sno37/1 plot no3 tingraenagar, pune, maharashtra,
3. Nature of work in which Contract Labour is employed or is to be Employed : Civil, electrical & mechainical
4. Maximum number of Contract Labour to be employed on any day : 500
5. Other Particular relevant to the Employment of Contract Labour : ----



  
**Registering Officer under Contract Labour  
(Regulation & Abolition) Act 1970 and  
Assistant Labour Commissioner Bathinda.**

**Assistant Labour Commissioner  
Bathinda**



**FORM-11**  
**{See Rule 18 (1)}**  
**CERTIFICATE OF REGISTRATION**

**No. R-05/2015**

**Dated ;29-09-2015**

**GOVERNMENT OF PUNJAB**  
**OFFICE OF THE REGISTERING OFFICER**

A certificate of registration containing the following particulars is hereby granted under sub section (2) of Section 7 of the Contract Labour (Regulation & Abolition) Act 1970 and the rule made there under to **M/s Mihit solar power pvt.ltd,**  
**Vill-khaira khurd, distt Mansa**

1. Nature of work : Solar Power Plant
2. Name and address of Contractors : (1) M/S Scheneider electric infrastructure limited, plot no 2B, IGL complex tower-3 \$th to 7<sup>th</sup> tower, Sec-126, noida, up,  
(2) M/S Bhandari engineering co.pvt.ltd, bhandari chowk, old bus stand bathinda.  
(3) M/S Ganges international pvt ltd 1<sup>st</sup> floor shop no 208, new grain markit, rajpura, patiala, punjab,  
(4) M/S Beniwal construction company pvt ltd, A-108 mansarovar, opp DPS School Pal road, jodhpur, rajasthan,
3. Nature of work in which Contract : Civil, electrical & mechianical  
Labour is employed or is to be Employed
4. Maximum number of Contract : 520  
Labour to be employed on any day
5. Other Particular relevant to the : ----  
Employment of Contract Labour



**Registering Officer under Contract Labour**  
**(Regulation & Abolition) Act 1970 and**  
**Assistant Labour Commissioner Bathinda.**

**Assistant Labour Commissioner**  
**Bathinda**



**FORM-11**  
**{See Rule 18 (1)}**  
**CERTIFICATE OF REGISTRATION**

**No. R-03/2015**

**Dated ;29-09-2015**

**GOVERNMENT OF PUNJAB**  
**OFFICE OF THE REGISTERING OFFICER**

A certificate of registration containing the following particulars is hereby granted under sub section (2) of Section 7 of the Contract Labour (Regulation & Abolition) Act 1970 and the rule made there under to **M/s Mihit solar power pvt.ltd,**  
**Vill-Jhande kalan, distt Mansa**

1. Nature of work : Solar Power Plant
2. Name and address of Contractors : (1) M/S Siemens limited, block no.6a,sec-18,Maruti industrial area, huda,gurgaon, haryana,  
(2) M/S Bhandari engineering co.pvt.ltd, bhandari chowk, old bus stand bathinda.  
(3) M/S Eeco green infratech pvt.ltd B1, Gulabi nagar ajmer road,sodala, haryana  
(4) M/S Eastern Bearing private limited,nathupura,kunmdli,distt sonipat, haryana.  
(5) M/S Addwatt solution private limited,310A pinnacle towerA block industrial Area,Sec-62 noida, up
3. Nature of work in which Contract Labour is employed or is to be Employed : Civil, electrical &mechanical
4. Maximum number of Contract Labour to be employed on any day : 425
5. Other Particular relevant to the Employment of Contract Labour : ----



**Registering Officer under Contract Labour**  
**(Regulation & Abolition) Act 1970 and**  
**Assistant Labour Commissioner Bathinda.**

**Assistant Labour Commissioner**  
**Bathinda**

ਵੱਲੋਂ ਪੰਜਾਬ ਬਿਜਲੀ ਇੰਸਪੈਕਟਰੇਟ

ਮੁੱਖ ਬਿਜਲੀ ਇੰਸਪੈਕਟਰ,  
ਪੰਜਾਬ ਸਰਕਾਰ, ਪਟਿਆਲਾ।

ਵੱਲੋਂ ਵਪੀਕ ਨਿਗਰਾਨ ਇੰਜਨੀਅਰ,  
ਪੰਜਾਬ ਰਾਜ ਟਰਾਂਸਮਿਸ਼ਨ ਕਾਰਪੋਰੇਸ਼ਨ ਲਿਮ.,  
ਟੀ.ਐਲ. ਮੰਡਲ, ਬਠਿੰਡਾ।

ਮੀਮੋ ਨੰ: 011046


ਮਿਤੀ: 23 FEB 2016

ਵਿਸ਼ਾ:- ਮੈ/ਸ ਮੀਹਤ ਸੋਲਰ ਪਾਵਰ, ਝੰਡੇ ਕਲਾਂ ਤੋਂ 66 ਕੇਵੀ ਸ/ਸ  
ਸਰਦੂਲਗੜ੍ਹ ਤੱਕ ਉਸਾਰੀ 66 ਕੇਵੀ ਦੇ ਨਿਰੀਖਣ ਸਬੰਧੀ।

ਹਵਾਲਾ:- ਤੁਹਾਡਾ ਪੱਤਰ ਨੰ 306 ਮਿਤੀ 23.02.2016 3112.. ਦੇ ਸਬੰਧ  
ਵਿੱਚ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਸਬੰਧਤ ਸਥਾਪਤੀ ਨੂੰ ਲੋਕ ਹਿੱਤ ਵਿੱਚ ਆਰਜ਼ੀ ਤੌਰ  
ਤੇ ਚਲਾਉਣ ਦੀ ਮੁਵਾਨਗੀ ਇਸ ਆਧਾਰ ਤੇ ਦਿੱਤੀ ਜਾਂਦੀ ਹੈ ਕਿ ਇਹ  
ਸਥਾਪਤੀਆਂ ਕੇਂਦਰੀ ਬਿਜਲੀ ਅਥਾਰਟੀ (ਸੁਰੱਖਿਆ ਨਾਲ ਸਬੰਧਤ ਮਾਪਦੰਡ ਅਤੇ  
ਬਿਜਲੀ ਸਪਲਾਈ) ਵਿਨਿਯਮ, 2010 ਦੇ ਵੱਖ ਵੱਖ ਰੂਲਾਂ ਦੇ ਅਨੁਕੂਲ ਉਸਾਰੀ  
ਗਈ ਹੈ।

ਸਥਾਪਤੀ ਦਾ ਨਿਰੀਖਣ ਬਾਅਦ ਵਿੱਚ ਕੀਤਾ ਜਾਵੇਗਾ।

  
ਮੁੱਖ ਬਿਜਲੀ ਇੰਸਪੈਕਟਰ,  
ਪੰਜਾਬ ਸਰਕਾਰ, ਪਟਿਆਲਾ।



ਪੰਜਾਬ ਬਿਜਲੀ ਇੰਸਪੈਕਟਰੇਟ

ਵਲੋ :

ਮੁੱਖ ਬਿਜਲੀ ਇੰਸਪੈਕਟਰ  
ਪੰਜਾਬ ਸਰਕਾਰ, ਪਟਿਆਲਾ ।

ਵੱਲ :

ਵਪਾਰਿਕ ਨਿਗਰਾਨ ਇੰਜੀਨੀਅਰ,  
ਪੰਜਾਬ ਰਾਜ ਪਾਵਰ ਕਾਰਪੋਰੇਸ਼ਨ ਲਿਮ.  
ਟੀ.ਐਲ. ਮੰਡਲ ਬਠਿੰਡਾ ।

ਮੀਮੇ ਨੰ. 10247


ਮਿਤੀ 23-1-16

ਵਿਸ਼ਾ : 66 ਕੇ.ਵੀ.ਏ ਲਾਇਨ ਮੀਹਤ ਸੇਲਰ ਪਾਵਰ ਪਲਾਂਟ ਬੇਹਰਾ ਖੁਰਦ  
ਤੇ 66 ਕੇ.ਵੀ. ਸਬ ਸਟੇਸ਼ਨ ਸਰਦੂਲਗੜ੍ਹ ।

ਹਵਾਲਾ : ਭੁਹਾਡੇ ਪੱਤਰ ਨੰ. 120 ਮਿਤੀ 25-01-2016 ਦੇ ਸਬੰਧ ਵਿਚ

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਸਬੰਧ ਸਥਾਪਤੀ ਨੂੰ ਚਲਾਉਣ ਦੀ ਆਰਜੀ ਪ੍ਰਵਾਨਗੀ ਦਿੱਤੀ  
ਜਾਂਦੀ ਹੈ । ਇਹ ਯਕੀਨੀ ਬਣਾਇਆ ਜਾਵੇ ਕਿ ਇਹ ਸਥਾਪਤੀ ਕੇਂਦਰੀ ਬਿਜਲੀ ਅਥਾਰਟੀ  
(ਚੁਰੋਖਿਆ ਨਾਲ ਸਬੰਧਤ ਮਾਪਦੰਡ ਅਤੇ ਬਿਜਲੀ ਸਪਲਾਈ) ਵਿਨਿਯਮ 2010 ਦੀਆਂ ਵੱਖ  
ਵੱਖ ਧਾਰਾਵਾਂ ਦੇ ਅਨੁਕੂਲ ਸਥਾਪਤ ਕੀਤੀ ਗਈ ਹੈ ।

ਸਥਾਪਤੀ ਦਾ ਨਰੀਖਣ ਬਾਅਦ ਵਿਚ ਕੀਤਾ ਜਾਵੇਗਾ ।

  
ਮੁੱਖ ਬਿਜਲੀ ਇੰਸਪੈਕਟਰ  
ਪੰਜਾਬ ਸਰਕਾਰ, ਪਟਿਆਲਾ

ਪੰਜਾਬ ਬਿਜਲੀ ਇੰਸਪੈਕਟਰੇਟ

ਵਲੋ :

ਮੁੱਖ ਬਿਜਲੀ ਇੰਸਪੈਕਟਰ  
ਪੰਜਾਬ ਸਰਕਾਰ, ਪਟਿਆਲਾ ।

ਵੱਲ :

ਵਪ੍ਰੀਕ ਨਿਗਰਾਨ ਇੰਜੀਨੀਅਰ,  
ਪੰਜਾਬ ਰਾਜ ਪਾਵਰ ਕਾਰਪੋਰੇਸ਼ਨ ਲਿਮ.  
ਟੀ.ਐਲ. ਮੰਡਲ ਬਠਿੰਡਾ ।

ਮੀਮੋ ਨੰ 10248

ਮਿਤੀ 28-1-16

ਵਿਸ਼ਾ : 66 ਕੇ.ਵੀ.ਏ ਲਾਇਨ ਮੀਹਤ ਸੈਲਰ ਪਾਵਰ ਪਲਾਂਟ ਮਾਨਬੋਰਡਾਂ ਤੋਂ  
66 ਕੇ.ਵੀ. ਸਬ ਸਟੇਸ਼ਨ ਸੰਘਾ ।

ਹਵਾਲਾ : ਤੁਹਾਡੇ ਪੱਤਰ ਨੰ 119 ਮਿਤੀ 25-01-2016 ਦੇ ਸਬੰਧ ਵਿਚ

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਸਬੰਧ ਸਥਾਪਤੀ ਨੂੰ ਚਲਾਉਣ ਦੀ ਆਗਜ਼ੀ ਪ੍ਰਵਾਨਗੀ ਦਿੱਤੀ  
ਜਾਂਦੀ ਹੈ । ਇਹ ਯਕੀਨੀ ਬਣਾਇਆ ਜਾਵੇ ਕਿ ਇਹ ਸਥਾਪਤੀ ਕੇਂਦਰੀ ਬਿਜਲੀ ਅਥਾਰਟੀ  
(ਸੁਰੱਖਿਆ ਨਾਲ ਸਬੰਧਤ ਮਾਪਦੰਡ ਅਤੇ ਬਿਜਲੀ ਸਪਲਾਈ) ਵਿਲਿਯਮ 2010 ਦੀਆਂ ਵੱਖ  
ਵੱਖ ਧਾਰਾਵਾਂ ਦੇ ਅਨੁਕੂਲ ਸਥਾਪਤ ਕੀਤੀ ਗਈ ਹੈ ।

ਸਥਾਪਤੀ ਦਾ ਨਰੀਖਣ ਬਾਅਦ ਵਿਚ ਕੀਤਾ ਜਾਵੇਗਾ ।

ਮੁੱਖ ਬਿਜਲੀ ਇੰਸਪੈਕਟਰ  
ਪੰਜਾਬ ਸਰਕਾਰ, ਪਟਿਆਲਾ

(Regd. Office: PSEB Head Office, The Mall, Patiala)  
 Office of Chief Engineer /Transmission System,  
 B-1, Shakti Vihar, Patiala.

Corporate Identity Number (CIN) U40109PB2010SGC033813

NOTIFICATION NO. 31 /TSN-207/Vol-IV

Dated: 3-11-15

It is hereby notified that Punjab State Power Corporation Ltd. (here-in-after called the PSPCL) proposes to undertake the following schemes/transmission works necessary for the dispersal/distribution of power for the improvement of the transmission and distribution system of the Punjab State Power Corporation Ltd.

**66KV TRANSMISSION WORKS FOR THE YEAR 2015-16**


Gr. No	Name of Work	Scope of work, Approx. Length of line in Kms.	Size of conductor / Cable Size	Approx. cost (Rs in Lacs)
1	66 KV SC on DC line from 220 KV S/S Amlah to 66 KV S/S Bhadson.	8.704 ckt. KM	0.2 sq inch	182
2	66 KV SC on DC line from Behram to 66 KV Mukandpur	10.518 KM	0.2 sq inch	219
3	Revised 66 KV Jhunir - Boha line T-off for 66 KV S/S Danewala (SC on DC)	1.521 KM	0.2 sq inch	34
	66 KV SC line on DC towers from M/s Allianz Group Solar Plant, Fattanwala to 66 KV S/S Fattanwala.	2.110 KM	0.2 sq inch	44
	66 KV SC line on DC towers from M/s Mihit Solar Power Plant Pvt. Ltd., Jhanda Kalan to 66 KV S/S Sardulgarh.	8.233 KM	0.2 sq inch	172
	66 KV SC line on DC towers from M/s P L Sunshine Ltd. Solar Plant Vill. Gamiwala to 66 KV S/S Boha.	1.503 KM	0.2 sq inch	34
	Revised 66 KV line from 220 KV S/S Rehana Jattan to 66 KV S/S Attowal ( TL No. 1 to 2)	0.151 KM revision original route 14.552	0.2 sq inch	Revised cost 303
	66 KV SC line on DC towers from M/s Oasis Green Energy Pvt. Ltd Solar Plant, Vill Bahadurpur, Distt Mansa to 66 KV S/S Bareta.	3.973 KM	0.2 sq inch	83
	66 KV line from 132 KV S/S Bhogpur - Bhulath SC on DC towers.	14.436 KM	0.2 sq inch	301





It is hereby notified that the PSPCL is undertaking and executing the sanctioned scheme and shall have the powers for placing of any Wires, Poles, Stays, Apparatus and Appliances for the Transmission and Distribution of Electricity or for Transmission of telegraphic or telephonic communications necessary for proper coordination of the works of PSPCL for the areas indicated above which the telegraph authority possess under Part-III of the Telegraphs Act. 1885 (XIII of 1885) in respect of telegraphs established or maintained and the provisions of section 164 of the Indian Electricity Act 2003 shall not apply to the same and therefore no separate notice of the scheme of PSPCL is required to be given.

This notification has been issued in respect of the provisions made under Section 164 of the Indian Electricity Act 2003 and Govt. of Punjab, Dept. of Power order no. S/O. 46/C.A. 36 /2003/S.164/2013 dt 19-6-2013 where in powers of Telegraph authority under part-III of the Indian Telegraph act, 1885 (Central Act no.13 of 1885) have been decided to be vested and exercised on PSPCL. Notice is hereby given that any person may raise objection if any/and or make any representation against the above scheme/transmission works within two month of issue of this notification. Thereafter no objection and or representation will be entertained and all schemes/transmission works will be deemed to be sanctioned with or without modifications as approved by the PSPCL. Necessary plans showing the tentative route of the Transmission Lines may be seen on any working day in the office of Dy. CE/TL, PSPCL, Jalandhar. Objections and/or representations in respect of the above schemes if any should be sent to the undersigned.

The above works have been planned to augment / add 66 KV transmission network in the state of Punjab so as to ensure quality and uninterrupted power supply to all type of existing/perspective electricity consumers of the state. These works are urgently required for ensuring quality power supply to the electricity consumers.

  
Dy CE/Trans. Lines (D),  
PSPCL, Patiala.

  
24/11/15

  
Chief Engineer/TS,  
Pb. State Power Corp. Ltd.  
B-1, Shakti Vihar, Patiala.





(ਰਜਿਸਟਰਡ ਆਫਿਸ ਪੰ:ਰਾ:ਬਿ:ਬੋ:ਹੈਡ ਆਫਿਸ ਬਿਲਡਿੰਗ ਦੀ ਮਾਲ, ਪਟਿਆਲਾ)  
 ਦਫਤਰ : ਮੁੱਖ ਇੰਜੀਨੀਅਰ / ਟੀ.ਐਸ., ਬੀ-1, ਸ਼ਕਤੀ ਵਿਹਾਰ, ਪਟਿਆਲਾ  
 ਕਾਰਪੋਰੇਟ ਆਈਡੈਂਟਿਟੀ ਨੰ: (CIN) U40109PB2010SGC033813

ਨੋਟੀਫਿਕੇਸ਼ਨ ਨੰ: 31 /ਟੀ.ਐਸ.ਐਨ-207 /Vol-IV

ਮਿਤੀ : 3-11-2015

ਇਹ ਦੱਸਿਆ ਜਾਂਦਾ ਹੈ ਕਿ ਪੰਜਾਬ ਰਾਜ ਪਾਵਰ ਕਾਰਪੋਰੇਸ਼ਨ ਲਿਮਟਿਡ (ਜਿਸ ਨੂੰ ਹੁਣ ਪੀ.ਐਸ.ਪੀ.ਸੀ.ਐਲ ਕਿਹਾ ਜਾਵੇਗਾ) ਵਲੋਂ ਨਿਮਨਲਿਖਤ ਸਕੀਮਾਂ/ਟਰਾਂਸਮਿਸ਼ਨ ਦੇ ਕੰਮ ਸ਼ੁਰੂ ਕਰਨ ਦਾ ਪ੍ਰਸਤਾਵ ਹੈ, ਜਿਹੜੀਆਂ ਪੰਜਾਬ ਰਾਜ ਪਾਵਰ ਕਾਰਪੋਰੇਸ਼ਨ ਲਿਮਟਿਡ ਦੇ ਸੰਚਾਲਣ ਅਤੇ ਵੰਡ ਵਿੱਚ ਸੁਧਾਰ ਕਰਨ ਲਈ ਬਿਜਲੀ ਦੀ ਡਿਸਪਰਸਲ /ਵੰਡ ਲਈ ਜ਼ਰੂਰੀ ਹਨ।

66 ਕੇਵੀ ਲਾਈਨਾਂ ਦੇ ਕੰਮ ਬਾਬਤ ਸਾਲ 2015-16

ਲੜੀ ਨੰ:	ਕੰਮ ਦਾ ਨਾਮ/ਸਕੋਪ ਆਫ ਵਰਕ	ਅੰਦਾਜ਼ਨ ਲਾਈਨ ਦੀ ਲੰਬਾਈ ਕਿ:ਮੀ:ਵਿੱਚ	ਸਾਈਜ਼ ਆਫ ਏ ਸੀ ਐਸ ਆਰ ਇੰਨ ਸੁਕੇਅਰ ਇੰਚ	ਅੰਦਾਜ਼ਨ ਕੀਮਤ (ਲੱਖਾਂ ਵਿੱਚ)
1	66 ਕੇਵੀ ਐਸ/ਸੀ ਆਨ ਡੀ/ਸੀ ਲਾਈਨ ਫਰਾਮ 220 ਕੇਵੀ ਸਬ ਸਟੇਸ਼ਨ ਅਮਲੋਹ ਟੂ 66 ਕੇਵੀ ਸਬ ਸਟੇਸ਼ਨ ਭਾਦਸੇ।	8.704 ckt. KM	0.2 sq inch	182 TSR-794
2	66 ਕੇਵੀ ਐਸ/ਸੀ ਆਨ ਡੀ/ਸੀ ਲਾਈਨ ਫਰਾਮ ਬਹਿਰਾਮ ਟੂ 66 ਕੇਵੀ ਮੁਕੰਦਪੁਰ।	10.518 KM	0.2 sq inch	219 TSR-806
3	ਰਿਵਾਇਜ਼ਡ 66 ਕੇਵੀ ਬੁਨੀਰ -ਬੋਹਾ ਲਾਈਨ ਟੀ-ਆਫ ਫਾਰ 66 ਕੇਵੀ ਸਬ ਸਟੇਸ਼ਨ ਦਾਨੇਵਾਲਾ (ਐਸ/ਸੀ ਆਨ ਡੀ/ਸੀ)	1.521 KM	0.2 sq inch	34 TSR-204
4	66 ਕੇਵੀ ਐਸ/ਸੀ ਲਾਈਨ ਆਨ ਡੀ/ਸੀ ਟਾਵਰਜ਼ ਫਰਾਮ ਮੈਸ. ਅਲਾਇੰਜ ਗਰੁੱਪ ਸੋਲਰ ਪਲਾਂਟ ਫੱਤਨਵਾਲਾ ਟੂ 66 ਕੇਵੀ ਸਬ ਸਟੇਸ਼ਨ ਫੱਤਨਵਾਲਾ।	2.110 KM	0.2 sq inch	44 TSR-269
5	66 ਕੇਵੀ ਐਸ/ਸੀ ਲਾਈਨ ਆਨ ਡੀ/ਸੀ ਟਾਵਰਜ਼ ਫਰਾਮ ਮੈਸੀ ਮਿਹਿਤ ਸੋਲਰ ਪਾਵਰ ਪਲਾਂਟ ਪ੍ਰਾਈਵੇਟ ਲਿਮਟਿਡ ਝੰਡਾ ਕਲਾਂ ਟੂ 66 ਕੇਵੀ ਸਬ ਸਟੇਸ਼ਨ ਸਰਦੂਲਗੜ।	8.233 KM	0.2 sq inch	172 TSR-268
6	66 ਕੇਵੀ ਐਸ/ਸੀ ਲਾਈਨ ਆਨ ਡੀ/ਸੀ ਟਾਵਰਜ਼ ਫਰਾਮ ਮੈਸ. ਪੀ.ਐਲ. ਸਨਸਾਈਨ ਲਿਮਟਿਡ ਸੋਲਰ ਪਲਾਂਟ ਪਿੰਡ ਗਮੀਵਾਲਾ ਟੂ 66 ਕੇਵੀ ਸਬ ਸਟੇਸ਼ਨ ਬੋਹਾ।	1.503 KM	0.2 sq inch	34 TSR-252
2)	ਰਿਵਾਇਜ਼ਡ 66 ਕੇਵੀ ਲਾਈਨ ਫਰਾਮ 220 ਕੇਵੀ ਸਬ ਸਟੇਸ਼ਨ ਰਿਹਾਣਾ ਜੱਟਾਂ ਟੂ 66 ਕੇਵੀ ਸਬ ਸਟੇਸ਼ਨ ਅੱਟੋਵਾਲ (ਟੀ.ਐਲ. 1 ਤੇ	0.151 KM revision	0.2 sq inch	Revised cost 303 F-2156
		original route 14.552		



8	66 ਕੇਵੀ ਐਸ/ਸੀ ਲਾਈਨ ਆਨ ਡੀ/ਸੀ ਟਾਵਰਜ਼ ਲਾਈਨ ਫਰਾਮ ਮੈਸ. ਓਰਿਸਿਸ ਗਰੀਨ ਐਨਰਜੀ ਪ੍ਰਾਈਵੇਟ ਲਿਮਟਿਡ ਸੋਲਰ ਪਲਾਂਟ ਪਿੰਡ ਬਹਾਦਰਪੁਰ, ਜ਼ਿਲਾ ਮਾਨਸਾ ਟੂ 66 ਕੇਵੀ ਸਬ ਸਟੇਸ਼ਨ ਬਰੇਟਾ।	3.973 KM	0.2 sq inch TSR-270	83
9	66 ਕੇਵੀ ਲਾਈਲ ਫਰਾਮ 132 ਕੇਵੀ ਸਬ ਸਟੇਸ਼ਨ ਭੋਗਪੁਰ -ਭੁਲੱਥ ਐਸ/ਸੀ ਲਾਈਨ ਆਨ ਡੀ/ਸੀ ਟਾਵਰਜ਼	14.436 KM	0.2 sq inch TSR-741	301


ਟਾਵਰਜ਼, ਪੋਲਜ਼, ਵਾਇਰਜ਼, ਸਟੇਅਜ਼ (ਖਿੱਚਾਂ) ਅਤੇ ਸਾਜ਼ ਸਮਾਨ ਲਗਾਉਣ ਲਈ ਜਿਹੜਾ ਕਿ ਉਕਤ ਦੱਸੇ ਅਤੇ ਦੂਰ ਸੰਚਾਰ ਨੈੱਟ ਵਰਕਸ ਲਈ ਟਰਾਂਸਮਿਸ਼ਨ ਲਾਈਨਾਂ ਲਗਾਉਣ ਲਈ ਜਿਹੜੀਆਂ ਕਿ ਇਹਨਾਂ ਲਾਈਨਾਂ ਦੇ ਚੰਗੀ ਤਰ੍ਹਾਂ ਕੰਮ ਕਰਨ ਲਈ ਜ਼ਰੂਰੀ ਹਨ। ਪੀ.ਐਸ.ਪੀ.ਸੀ.ਐਲ.ਦਾ ਇਰਾਦਾ ਹੈ ਕਿ ਉਹ ਆਪਣੇ ਉਨ੍ਹਾਂ ਅਧਿਕਾਰਾਂ ਦੀ ਵਰਤੋਂ ਕਰੇ, ਜਿਹੜੇ ਕਿ ਉਸ ਨੂੰ ਪਾਰਟ-3 ਆਫ ਟੈਲੀਗਰਾਫਿਕ ਅਥਾਰਟੀਜ਼ ਵਲੋਂ ਟੈਲੀਗਰਾਫ ਐਕਟ-1885 (XIII- ਆਫ 1885) ਅਧੀਨ ਮਿਲੇ ਹਨ। ਇਨ ਰਿਸਪੈਕਟ ਆਫ ਟੈਲੀਗਰਾਫ ਇਸਟੈਬਲਿਸ਼ ਅਤੇ ਮੇਨਟੇਨ ਅਧੀਨ ਸੈਕਸ਼ਨ 164 ਆਫ ਇੰਡੀਅਨ ਇਲੈਕਟ੍ਰੀਸਿਟੀ ਐਕਟ -2003 ਲਾਗੂ ਨਹੀਂ ਹੁੰਦਾ ਅਤੇ ਉਥੇ ਪੀ.ਐਸ.ਪੀ.ਸੀ.ਐਲ. ਦੀ ਸਕੀਮ ਲਈ ਕੋਈ ਵੱਖਰਾ ਨੋਟਿਸ ਦੇਣ ਦੀ ਲੋੜ ਨਹੀਂ।

ਇਹ ਨੋਟੀਫਿਕੇਸ਼ਨ ਬਿਜਲੀ ਐਕਟ-2003 ਦੀ ਸੈਕਸ਼ਨ 164 ਦੀਆਂ ਨਵੀਆਂ ਧਾਰਾਵਾਂ ਮੁਤਾਬਿਕ ਜਾਰੀ ਕੀਤੀ ਜਾਂਦੀ ਹੈ ਅਤੇ ਪਾਵਰ ਡਿਪਾਰਟਮੈਂਟ, ਪੰਜਾਬ ਸਰਕਾਰ ਦੇ ਹੁਕਮ ਨੰ: S/O. 46/C.A. 36 /2003/S.164/2013 dt 19-6-2013 ਅਨੁਸਾਰ ਇੰਡੀਅਨ ਟੈਲੀਗਰਾਫ ਐਕਟ-1885 (ਸੈਂਟਰਲ ਐਕਟ 13 ਆਫ 1985) ਦੇ ਪਾਰਟ 3 ਅਧੀਨ ਟੈਲੀਗਰਾਫ ਅਥਾਰਟੀ ਦੀਆਂ ਪਾਵਰਜ਼ ਪੀ.ਐਸ.ਪੀ.ਸੀ.ਐਲ.ਨੂੰ vested and exercised ਕਰਨ ਦਾ ਫੈਸਲਾ ਕੀਤਾ ਜਾਂਦਾ ਹੈ। ਇਸ ਸਬੰਧੀ ਨੋਟਿਸ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ ਜੇ ਕਿਸੇ ਵਿਅਕਤੀ ਨੂੰ ਉਪਰੋਕਤ ਸਕੀਮ/ਟਰਾਂਸਮਿਸ਼ਨ ਲਾਈਨਾਂ ਦੇ ਕੰਮਾਂ ਸਬੰਧੀ ਕੋਈ ਇਤਰਾਜ਼ ਹੋਵੇ ਤਾਂ ਉਹ ਆਪਣੀ ਪ੍ਰਤੀ ਵੇਦਨਾ ਇਸ ਨੋਟੀਫਿਕੇਸ਼ਨ ਦੇ ਜਾਰੀ ਹੋਣ ਤੋਂ 2 ਮਹੀਨੇ ਦੇ ਅੰਦਰ ਅੰਦਰ ਦੇ ਸਕਦਾ ਹੈ। ਇਸ ਤੋਂ ਬਾਅਦ ਕੋਈ ਇਤਰਾਜ਼ ਜਾਂ ਪ੍ਰਤੀ ਵੇਦਨਾ ਸਵੀਕਾਰ ਨਹੀਂ ਕੀਤੀ ਜਾਵੇਗੀ ਅਤੇ ਸਾਰੀ ਸਕੀਮ/ਟਰਾਂਸਮਿਸ਼ਨ ਲਾਈਨਾਂ ਦੇ ਕੰਮ ਬਿਨਾਂ ਕੋਈ ਸੋਧ ਕੀਤੇ ਜਾਂ ਸੋਧ ਕਰਕੇ ਪੀ.ਐਸ.ਪੀ.ਸੀ.ਐਲ. ਦੀ ਮੰਨਜ਼ੂਰੀ ਮੁਤਾਬਿਕ ਲਾਗੂ ਮੰਨੇ ਜਾਣਗੇ। ਇਸ ਸਿਲਸਿਲੇ ਵਿੱਚ ਲੋੜੀਂਦੇ ਆਰਜ਼ੀ ਪਲਾਨ ਜਿਨ੍ਹਾਂ ਵਿੱਚ ਟਰਾਂਸਮਿਸ਼ਨ ਲਾਈਨਾਂ ਦੇ ਰਸਤੇ ਵਿਖਾਏ ਗਏ ਹਨ, ਕਿਸੇ ਵੀ ਕੰਮਕਾਰ ਵਾਲੇ ਦਿਨ ਉਪ ਮੁੱਖ ਇੰਜੀਨੀਅਰ/ਟੀ.ਐਲ., ਪੀ.ਐਸ.ਪੀ.ਸੀ.ਐਲ., ਜਲੰਧਰ ਦੇ ਦਫਤਰ ਵਿਚ ਵੇਖੇ ਜਾ ਸਕਦੇ ਹਨ। ਉਪਰੋਕਤ ਸਕੀਮਾਂ ਸਬੰਧ ਜੋ ਕੋਈ ਇਤਰਾਜ਼ ਅਤੇ ਪ੍ਰਤੀ ਵੇਦਨਾ ਹੋਵੇ ਤਾਂ ਨਿਮਨਹਸਤਾਖਰ ਨੂੰ ਭੇਜੇ ਜਾਣ।

ਉਪਰੋਕਤ ਕੰਮ ਪੰਜਾਬ ਰਾਜ ਦੇ 66 ਕੇਵੀ ਟਰਾਂਸਮਿਸ਼ਨ ਨੈੱਟਵਰਕ ਵਿੱਚ ਵਾਧਾ/ ਸਮਰੱਥਾ ਵਧਾਉਣ ਦੇ ਮੰਤਵ ਕਰਕੇ ਪਲਾਨ ਕੀਤੇ ਗਏ ਹਨ ਤਾਂ ਜੋ ਰਾਜ ਦੇ ਸਾਰੇ ਤਰਾਂ ਦੇ ਮੌਜੂਦਾ/ਸੰਭਾਵੀ ਬਿਜਲੀ ਖਪਤਕਾਰਾਂ ਨੂੰ ਨਿਰਵਿਘਨ ਅਤੇ ਵਧੀਆ ਬਿਜਲੀ ਸਪਲਾਈ ਦਿੱਤੀ ਜਾ ਸਕੇ। ਇਹ ਕੰਮ ਬਿਜਲੀ ਖਪਤਕਾਰਾਂ ਨੂੰ ਮਿਆਰੀ ਪਾਵਰ ਸਪਲਾਈ ਯਕੀਨੀ ਬਣਾਉਣ ਲਈ ਅਤਿਅੰਤ ਲੋੜੀਂਦੇ ਹਨ।

ਉਪ ਮੁੱਖ ਇੰਜੀਨੀਅਰ/ਟਰਾਂਸਮਿਸ਼ਨ ਲਾਈਨ(ਡ),  
ਪੀ.ਐਸ.ਪੀ.ਸੀ.ਐਲ., ਪਟਿਆਲਾ  
2-11-15

ਮੁੱਖ ਇੰਜੀਨੀਅਰ/ਟੀ.ਐਲ.,  
ਪੰਜਾਬ ਸਟੇਟ ਪਾਵਰ ਕਾਰਪੋਰੇਸ਼ਨ ਲਿਮਟਿਡ,  
ਬੀ-1, ਸ਼ੁਕਤੀ ਵਿਹਾਰ, ਪਟਿਆਲਾ



## Punjab State Power Corporation Limited

(Regd. Office: PSEB Head Office, The Mall, Patiala)  
Office of Chief Engineer /Transmission System,  
B-1, Shakti Vihar, Patiala.

Corporate Identity Number (CIN) U40109PB2010SGC033813

NOTIFICATION NO. 29 /TSN-207/Vol-IV

Dated: 7-9-15

It is hereby notified that Punjab State Power Corporation Ltd. (here-in-after called the PSPCL) proposes to undertake the following schemes/transmission works necessary for the dispersal/distribution of power for the improvement of the transmission and distribution system of the Punjab State Power Corporation Ltd.

### 66KV TRANSMISSION WORKS FOR THE YEAR 2014-15

Sr. No	Name of Work	Scope of work, Approx. Length of line in Kms.	Size of conductor / Cable Size	Approx. cost (Rs in Lacs)
1	66 KV line from M/s Welspun Solar Punjab (P) Ltd., Teona pujarian to 66 KV Jagah Ram Tirath.	1.775 ckt. KM	0.2 sq inch	37
2	Shifting of 66 KV line from 66 KV Dabwali Road, Bathinda at new proposed 66 KV S/S I.G.C., Bathinda.	1.168 KM	0.2 sq inch	67
3	Revised route plan for raising of existing 66 KV Sunam - Patran HRP (SC on DC) inside Taj City near 66 KV S/S Sunam.	0.733 KM.	0.125 sq inch	8
4	66 KV DC line from 220 KV S/S Sunam to join solid tap point for 66 KV S/S Sheron.	1.456 KM	0.2 sq inch	45
5	Raising height of 66 KV Patti - Harike H.R.P. line and maintaining distance of towers from the centre of road (NH-15 Amritsar - Tarntaran - Harike section)	U/G cable 0.161 ckt. KM	240 mm <sup>2</sup>	39
6	66 KV DC line 220 KV S/S Sandhwan to Kotkapura (Replacement of existing Rail Pole line).	0.893 KM 4.457 KM	0.4 sq inch 0.2 sq inch	190
7	Shifting of 66 KV, Rail Pole line from BBMB Sangrur to Partan Ckt. No. 1 from the premises of M/s Kuku Petrol Pump, Sangrur.	0.463 KM	0.15 sq inch	8



8	66 KV line from 132 KV Jadla to 66 KV Balachaur (SC on DC)	8.106 KM	0.2 sq inch	168
9	66 KV line from 220 KV Mahilpur to 66 KV Saila Khurd (SC on DC ) Replacement of Existing HRP line.	12.526 KM	0.2 sq inch	259
10	T - off 66 KV Kharar - Majra line to Teur S/S (SC on DC)	1.157 KM	0.2 sq inch	24
11	Raising of existing 66 KV HRP line (Ckt. 1) from BBMB Sangrur to Partan on NH -64 Patiala - Bathinda road.	0.541 KM	0.2 sq inch	20
12	Raising of existing 66 KV HRP line (Ckt. 2) from BBMB Sangrur to Partan on NH -64 Patiala - Bathinda road.	0.479 KM	0.2 sq inch	15
13	Shifting/Raising of 66 KV Kharar - Badali Ala Singh line in the Land of Sh. Bhagwant Singh	0.845 ckt. KM (Resagging)	0.125 sq inch	5
14	66 KV SC line on DC towers from M/s Purshotam Industries Pvt. Ltd. Solar Power Plant, Bajak to 66 KV S/S Nandgarh (Ghudha)	2.355 KM	0.2 sq inch	49
15	Shifting of 66 KV T- off line for Sailwala.	0.494 KM	0.2 sq inch	11
16	66 KV Sarai Naga - Wada Kishanpura T- off line for 66 KV S/S Maur (SC on DC)	0.300 KM	0.2 sq inch	10
17	66 KV line from M/s Azure Power Make Pvt. Ltd. Solar Plant Vill. Bhiwala to 66 KV S/S Bhiwala (SC on DC)	0.298 KM	0.2 sq inch	10
18	Revised route plan of 66 KV line from 220 KV S/S Himmatpura to 66 KV S/S Diwana (SC on DC)-- 220 KV S/S Himmatpura to Tower no. 7	1.105 KM	0.2 sq inch	26
19	Addition & alteration/raising of 66 KV DC line from 66 KV S/S Sector-88 to 66 KV S/S Phase-9, Mohali.	1.243 KM	0.2 sq inch	7
20	66 KV T-off Sahnewal - Kohara line for 66 KV S/S Jandiali (SC on DC)	1.461 KM	0.2 sq inch	32
21	Revised route plan of 66 KV line from M/s Gill Aqua Hydro Generation Company Pvt. Ltd., Mudde to 66 KV S/S Ranipur, SC on SC.	3.100 KM	0.15 sq. inch	64
22	66 KV line SC on DC towers from Mihit Pvt. Ltd. Solar Plant Khera Khurd - Sardulgarh.	U/G cable 0.522 ckt. KM O/H line 4.164 KM	240 mm <sup>2</sup> 0.2 sq. inch	101 77


It is hereby notified that the PSPCL is undertaking and executing the sanctioned scheme and shall have the powers for placing of any Wires, Poles, Stays, Apparatus and Appliances for the Transmission and Distribution of Electricity or for Transmission of





telegraphic or telephonic communications necessary for proper coordination of the works of PSPCL for the areas indicated above which the telegraph authority possess under Part-III of the Telegraphs Act, 1885 (XIII of 1885) in respect of telegraphs established or maintained and the provisions of section 164 of the Indian Electricity Act 2003 shall not apply to the same and therefore no separate notice of the scheme of PSPCL is required to be given.

This notification has been issued in respect of the provisions made under Section 164 of the Indian Electricity Act 2003 and Govt. of Punjab, Dept. of Power order no. S/O. 46/C.A. 36 /2003/S.164/2013 dt 19-6-2013 where in powers of Telegraph authority under part-III of the Indian Telegraph act, 1885 (Central Act no.13 of 1885) have been decided to be vested and exercised on PSPCL. Notice is hereby given that any person may raise objection if any/and or make any representation against the above scheme/transmission works within two month of issue of this notification. Thereafter no objection and or representation will be entertained and all schemes/transmission works will be deemed to be sanctioned with or without modifications as approved by the PSPCL. Necessary plans showing the tentative route of the Transmission Lines may be seen on any working day in the office of Dy. CE/TL, PSPCL, Jalandhar. Objections and/or representations in respect of the above schemes if any should be sent to the undersigned.

The above works have been planned to augment / add 66 KV transmission network in the state of Punjab so as to ensure quality and uninterrupted power supply to all type of existing/perspective electricity consumers of the state. These works are urgently required for ensuring quality power supply to the electricity consumers.

  
7/9/15  
Dy. CE/Trans. Lines (D),  
PSPCL, Patiala.

  
4.8.15

  
7.8.15  
Chief Engineer/TS,  
Pb. State Power Corp. Ltd.  
B-1, Shakti Vihar, Patiala.





## Punjab state Power Corporation Limited

**Regd. Off.: PSEB H.O., The Mall, Patiala-147001**

**Corporate Identification Number (CIN) : U40109PB2010SGC033813, website:- www.pspcl.in**

**OFFICE OF CHIEF ENGINEER/ TRANSMISSION SYSTEM, B-1, SHAKTI VIHAR, PATIALA**

Notification No. 29/ TSN-207/Vol-IV

Dated: 7-09-2015

It is hereby notified that Punjab State Power Corporation Ltd. (here-in- after called the PSPCL) proposes to undertake the following schemes/ Transmission works necessary for the dispersal/ distribution of power of the improvement of the Transmission and Distribution system of the Punjab State Power Corporation Ltd.

### 66KV TRANSMISSION WORKS FOR THE YEAR 2014-15

Sr. No.	Name of Work	Scope of Work, Approx. Length of line in Kms.	Size of Conductor/ Cable Size	Approx Cost (Rs. In Lacs)
1	66 KV line from M/s Welspun Solar Punjab (P) Ltd., Teona pujan to 66 KV Jagah Ram Tirath.	1.775 ckt. KM	0.2 sq inch	37
2	Shifting of 66 KV line from 66 KV Dabwali Road. Bathinda at new proposed 66 KV S/S I.G.C., Bathinda.	1.168 KM	0.2 sq inch	67
3	Revised route plan for raising of existing 66 KV Sunam - Patran HRP (SC on DC) inside Taj City near 66 KV S/S Sunam.	0.733 KM	0.125 sq inch	8
4	66 KV DC line from 220 KV S/S Sunam to join solid tap point for 66 KV S/S Sheron.	1.456 KM	0.2 sq inch	45
5	Raising height of 66 KV Patti - Harike H.R.P. line and maintaining distance of towers from the centre of road (NH-15 Amritsar-Tarnataran- Harike section)	U/G Cable 0.161 ckt. KM	240 mm <sup>2</sup>	39
6	66 KV DC line 220 KV S/S Sandhwan to Kotkapura (Replacement of existing Rail Pole line).	0.893 KM 4.457 KM	0.4 sq inch 0.2 sq inch	190
7	Shifting of 66 KV Rail Pole line from BBMB Sangrur to Partan Ckt. No. 1 from the premises of M/s Kuku Petrol Pump, Sangrur.	0.463 KM	0.15 sq inch	8
8	66 KV line from 132 KV Jadia to 66 KV Balachaur (SC on DC)	8.105 KM	0.2 sq. inch	168
9	66 KV line from 220 KV Mahilpur to 66 KV Salla Khurd (SC on DC) Replacement of Existing HRP line.	12.526 KM	0.2 sq. inch	259
10	T- off 66 KV Kharar - Majra line to Teur S/S (SC on DC)	1.157 KM	0.2 sq. inch	24
11	Raising of existing 66 KV HRP line (Ckt. 1) from BBMB Sangrur to Partan on NH -64 Patiala -Bathinda road.	0.541 KM	0.2 sq. inch	20
12	Raising of existing 66 KV HRP line (Ckt. 2) from BBMB Sangrur to Partan on NH -64 Patiala - Bathinda road.	0.479 KM	0.2 sq. inch	15
13	Shifting/Raising of 66 KV Kharar - Badali Ala Singh line in the Land of Sh. Bhagwant Singh	0.845 ckt. KM (Resagging)	0.125 sq inch	5
14	66 KV SC line on DC towers from M/s Purshotam Industries Pvt. Ltd. Solar Power Plant, Bajak to 66 KV S/S Nandgarh (Ghudha)	2.355 KM	0.2 sq. inch	49
15	Shifting of 66 KV T- off line for Sailwala.	0.494 KM	0.2 sq. inch	11
16	66 KV Sarai Naga - Wada Kishanpura T- off line for 66 KV S/S Mair (SC on DC)	0.300 KM	0.2 sq. inch	10
17	66 KV line from M/s Azure Power Make Pvt. Ltd. Solar Plant, Villi Bhitwala to 66 KV S/S Bhitwala (SC on DC)	0.298 KM	0.2 sq. inch	10
18	Revised route plan of 66 KV line from 220 KV S/S Himmatpura to 66 KV S/S Diwana (SC on DC)- 220 KV S/S Himmatpura to Tower no. 7	1.105 KM	0.2 sq. inch	26
19	Addition & alteration/raising of 66 KV DC line from 66 KV S/S Sector-88 to 66 KV S/S Phase- 9, Mohali	1.243 KM	0.2 sq. inch	7
20	66 KV T-off Sahnewal - Kohara line for 66 KV S/S Jandiali (SC on DC)	1.461 KM	0.2 sq. inch	32
21	Revised route plan of 66 KV line from M/s Gali Aqua Hydro Generation Company Pvt. Ltd., Murde to 66 KV S/S Ranipur, SC on SC.	3.100 KM	0.15 sq. inch	64
22	66 KV line SC on DC towers from Mihit Pvt. Ltd. Solar Plant Khara Khurd - Sardulgarh.	U/G-Cable 0.522 ckt. KM O/H Line 4.164 Km.	240 mm <sup>2</sup> 0.2 sq inch	101 77

It is hereby notified that the PSPCL is undertaking and executing the sanctioned scheme and shall have the powers for placing of any wires, poles, Stays Apparatus and Appliances for the Transmission and Distribution of Electricity on for Transmission of telegraphic or telephonic communications necessary for proper coordination of the works of PSPCL for the areas indicated above which the telegraph authority possess under Part-III of the Telegraphs Act, 1885 (XIII of 1885) the provisions of section 164 of the Indian Electricity Act 2003 shall in respect of telegraphs established or maintained and the provisions of section 164 of the Indian Electricity Act 2003 shall not apply to the same and therefore no separate notice of the scheme of PSPCL is required to be given.

This notification has been issued in respect of the provisions made under Section 164 of the Indian Electricity Act 2003 and Govt. of Punjab, Dept. of Power order no. S/O. 46/C.A. 6/2003/S.164/2013 dt 19-6-2013 where in powers of Telegraph authority under part-III of the Indian Telegraph act, 1885 (Central Act no.13 of 1885) have been decided to be vested and exercised on PSPCL. Notice is here by given that any person may raise objection if any/and or make any representation against the above scheme/transmission works within two month of issue of this notification. Thereafter no objection and or representation will be entertained and all schemes/transmission works will be deemed to be sanctioned with or without modifications as approved by the PSPCL. Necessary plans showing the tentative route of the Transmission Lines may be seen on any working day in the office of Dy. CE/TL, PSPCL, Jalandhar. Objections and/or representations in respect of the above schemes if any should be sent to the undersigned.

The above works have been planned to augment / add 66 KV transmission network in the state of Punjab so as to ensure quality and uninterrupted power supply to all type of existing/perspective electricity consumers of the state. These works are urgently required for ensuring quality power supply to the electricity consumers.

Dy. CE/ Trans. Lines (D),  
PSPCL, Patiala

Chief Engineer/ TS,  
Ph. State Power Corp. Ltd. B-1, Shakti Vihar, Patiala

Energy is Life Conserve It



(Regd. Office: PSEB Head Office, The Mall, Patiala)  
 Office of Chief Engineer /Transmission System,  
 B-1, Shakti Vihar, Patiala.

Corporate Identity Number (CIN) U40109PB2010SGC033813

Notification No. 30 /TSN-207/Vol-IV

Dated: 1-X-2015

It is hereby notified that Punjab State Power Corporation Ltd. (here-in-after called the PSPCL) proposes to undertake the following schemes/transmission works necessary for the dispersal/distribution of power for the improvement of the transmission and distribution system of the Punjab State Power Corporation Ltd.

**66KV TRANSMISSION WORKS FOR THE YEAR 2014-15**

Sr. No	Name of Work	Scope of work, Approx. Length of line in Kms.	Size of conductor / Cable Size	Approx. cost (Rs in Lacs)
1	66 KV line from 66 KV sub station Jallah to 66 KV sub station Tohra (SC on DC)	6.175 ckt. KM	0.2 sq inch	128
2	66 KV Mangwal – Bhalwan line (SC on DC).	7.066 KM	0.2 sq inch	146
3	11 KV line from Narot Jaimal Singh to Khojki Chak Feeder for Ujh River Crossing.	0.350 KM.	7/2.24 mm (GSS Wire)	5
4	66 KV Jhander – Jagdev kalan line (SC on DC)	4.035 KM	0.2 sq inch	84
5	66 KV line from M/s Radiant Solar Energies Pvt. Ltd. Solar Power Plant 3 MW Pathrala to 66 KV sub station Pathrala (SC on DC)	1.045 KM 0.341 KM	0.2 sq inch 0.15 sq inch	29
6	66 KV Ranipur – Dhar line up to T-off point for 66 KV Manwal SC on DC.	2.870 KM	0.2 sq inch	60
7	Shifting of 66 KV Sangat – Mehta SC line on DC towers from the plot of Smt. Sulekha Garg.	0.576 KM	0.2 sq inch	14
8	66 KV line from M/s Azure Power Make Pvt. Ltd. Solar Plant, Killianwali to 66 KV sub station Killianwali (SC on DC)	5.960 KM	0.2 sq inch	123



9	66 KV SC on DC towers from M/s Mihit Solar Power Plant Pvt. Ltd. , Mannkhera to 66 KV sub station Sangha.	3.280 KM	0.2 sq inch	68
10	66 KV SC line on DC towers from M/s Solaire power Pvt. Ltd., Usman khera to 66 KV sub station Kalar Khera.	4.525 KM	0.2 sq inch	94

It is hereby notified that the PSPCL is undertaking and executing the sanctioned scheme and shall have the powers for placing of any Wires, Poles, Stays, Apparatus and Appliances for the Transmission and Distribution of Electricity or for Transmission of telegraphic or telephonic communications necessary for proper coordination of the works of PSPCL for the areas indicated above which the telegraph authority possess under Part-III of the Telegraphs Act. 1885 (XIII of 1885) in respect of telegraphs established or maintained and the provisions of section 164 of the Indian Electricity Act 2003 shall not apply to the same and therefore no separate notice of the scheme of PSPCL is required to be given.

This notification has been issued in respect of the provisions made under Section 164 of the Indian Electricity Act 2003 and Govt. of Punjab, Dept. of Power order no. S/O. 46/C.A. 36 /2003/S.164/2013 dt 19-6-2013 where in powers of Telegraph authority under part-III of the Indian Telegraph act, 1885 (Central Act no.13 of 1885) have been decided to be vested and exercised on PSPCL. Notice is hereby given that any person may raise objection if any/and or make any representation against the above scheme/transmission works within two month of issue of this notification. Thereafter no objection and or representation will be entertained and all schemes/transmission works will be deemed to be sanctioned with or without modifications as approved by the PSPCL. Necessary plans showing the tentative route of the Transmission Lines may be seen on any working day in the office of Dy. CE/TL Circle, PSPCL, Jalandhar. Objections and/or representations in respect of the above schemes if any should be sent to the undersigned.

The above works have been planned to augment / add 66 KV transmission network in the state of Punjab so as to ensure quality and uninterrupted power supply to all type of existing/perspective electricity consumers of the state. These works are urgently required for ensuring quality power supply to the electricity consumers.

Dy. CE/Trans. Lines (D),  
PSPCL, Patiala.

1.10.15

Chief Engineer/TS,  
Pb. State Power Corp. Ltd.  
B-1, Shakti Vihar, Patiala.

1.10.15





**PSPCL**  
Powering Punjab, Enriching Lives

# ਪੰਜਾਬ ਸਟੇਟ ਪਾਵਰ ਕਾਰਪੋਰੇਸ਼ਨ ਲਿਮਟਿਡ

ਰਜਿ. ਦਫਤਰ ਪੰ. ਰਾ. ਬਿ. ਬੋ. ਹੋਂਡ ਆਫਿਸ, ਬਿਲਡਿੰਗ ਦਿ ਮਾਲ ਪਟਿਆਲਾ 147001

ਦਫਤਰ : ਮੁੱਖ ਇੰਜੀਨੀਅਰ/ ਟੀ. ਐੱਸ., ਬੀ-1, ਸ਼ਕਤੀ ਵਿਹਾਰ, ਪਟਿਆਲਾ

ਕਾਰਪੋਰੇਟ ਆਈਡੈਂਟਿਟੀ ਨੰ. U40109PB2010SGC033813, Website: www.pspcl.in

ਨੋਟੀਫਿਕੇਸ਼ਨ ਨੰ. 30/ ਟੀ. ਐੱਸ. ਐੱਨ. 207/Vol-IV

ਮਿਤੀ : 1-x-2015

ਇਹ ਦੱਸਿਆ ਜਾਂਦਾ ਹੈ ਕਿ ਪੰਜਾਬ ਰਾਜ ਪਾਵਰ ਕਾਰਪੋਰੇਸ਼ਨ ਲਿਮਟਿਡ (ਜਿਸ ਨੂੰ ਹੁਣ ਪੀ. ਐੱਸ. ਪੀ. ਸੀ. ਐੱਲ. ਕਿਹਾ ਜਾਵੇਗਾ) ਵਲੋਂ ਨਿਮਨਲਿਖਤ ਸਕੀਮਾਂ/ਟਰਾਂਸਮਿਸ਼ਨ ਦੇ ਕੰਮ ਸ਼ੁਰੂ ਕਰਨ ਦਾ ਪ੍ਰਸਤਾਵ ਹੈ, ਜਿਹੜੀਆਂ ਪੰਜਾਬ ਰਾਜ ਪਾਵਰ ਕਾਰਪੋਰੇਸ਼ਨ ਲਿਮਟਿਡ ਦੇ ਸੰਚਾਲਣ ਅਤੇ ਵੰਡ 'ਚ ਸ਼ੁਰੂ ਕਰਨ ਲਈ ਬਿਜਲੀ ਦੀ ਡਿਸਪਰਸਲ/ਵੰਡ ਲਈ ਜ਼ਰੂਰੀ ਹਨ।

66 ਕੇ. ਵੀ. ਲਾਈਨਾਂ ਦੇ ਕੰਮ ਬਾਬਤ ਸਾਲ 2015-16

ਲੜੀ ਨੰ.	ਕੰਮ ਦਾ ਨਾਂ/ ਸਕੇਪ ਆਫ ਵਰਕ	ਅੰਦਾਜ਼ਨ ਲਾਈਨ ਦੀ ਲੰਬਾਈ ਕਿ. ਮੀ. ਵਿਚ	ਸਾਈਜ਼ ਆਫ ਟੀ. ਸੀ. ਐੱਸ. ਆਰ. ਇਨ ਸਕਵੇਰ ਇੰਚ	ਅੰਦਾਜ਼ਨ ਕੀਮਤ (ਲੱਖਾਂ 'ਚ)
1.	66 ਕੇ ਵੀ ਲਾਈਨ ਫਰਾਮ 66 ਕੇ ਵੀ ਸਬ ਸਟੇਸ਼ਨ ਜਲਾਹ ਟੂ 66 ਕੇ ਵੀ ਸਬ ਸਟੇਸ਼ਨ ਟੋਹੜਾ (ਐੱਸ/ਸੀ ਆਨ ਡੀ/ਸੀ)	6.175 CKT. KM	0.2 Sq. inch	128
2.	11 ਕੇ ਵੀ ਮੋਗਵਾਲ, ਫਲਵਾਨ ਲਾਈਨ (ਐੱਸ/ਸੀ ਆਨ ਡੀ/ ਸੀ)	7.066 KM	0.2 Sq. inch	146
3.	11 ਕੇ ਵੀ ਲਾਈਨ ਫਰਾਮ ਨਰੋਟ ਜੇਮਲ ਸਿੰਘ ਟੂ ਚੌਥੀ ਚੌਕ ਫੀਡਰ ਵਾਰ ਉੱਚ ਗੇਜ਼ਰ ਕਰਾਸਿੰਗ	0.350 KM	7/2.24mm(GSS Wire)	5
4.	66 ਕੇ ਵੀ ਫੰਡਰ ਜਗਦੇਵ ਕਲਾਂ ਲਾਈਨ (ਐੱਸ/ਸੀ ਆਨ ਡੀ/ਸੀ)	4.035 KM	0.2 Sq. inch	4
5.	66 ਕੇ ਵੀ ਲਾਈਨ ਫਰਾਮ ਮੈਸ. ਰੋਡੀਐਂਟ ਸੋਲਰ ਐਨਰਜੀ ਪ੍ਰਾਈਵੇਟ ਲਿਮ., ਸੋਲਰ ਪਾਵਰ ਪਲਾਂਟ 3 ਮੋਗਵਾਲ ਪਥਰਾਲਾ ਟੂ 66 ਕੇ ਵੀ ਸਬ ਸਟੇਸ਼ਨ ਪਥਰਾਲਾ (ਐੱਸ/ਸੀ ਆਨ ਡੀ/ਸੀ)	1.045 KM 0.341 KM	0.2 Sq. inch 0.15 Sq. inch	29
6.	66 ਕੇ ਵੀ ਰਾਨੀਪੁਰ-ਢਾਹ ਲਾਈਨ ਅਪ ਟੂ ਟੀ-ਆਫ ਪੁਆਇੰਟ ਢਾਹ 66 ਕੇ ਵੀ ਮਨਵਾਲ (ਐੱਸ/ਸੀ ਆਨ ਡੀ/ਸੀ)	2.870 KM	0.2 Sq. inch	60
7.	ਬਿਥਰਿਗ 66 ਕੇ ਵੀ ਸੰਗਤ-ਮਹਿਤਾ ਐੱਸ/ ਸੀ ਲਾਈਨ ਆਨ ਡੀ/ਸੀ ਟਾਵਰ ਫਰਾਮ ਦਾ ਪਲਾਂਟ ਆਫ ਸ਼ੀਮਤੀ ਸੁਲੇਖਾ ਗਰਾ	0.576 KM	0.2 Sq. inch	14
8.	66 ਕੇ ਵੀ ਲਾਈਨ ਫਰਾਮ ਮੈਸ. ਅਜੂਰ ਪਾਵਰ ਮੌਕ ਪ੍ਰਾਈਵੇਟ ਲਿਮ. ਸੋਲਰ, ਪਲਾਂਟ ਕੋਲਿਆਵਾਲੀ ਟੂ 66 ਕੇ ਵੀ ਸਬ ਸਟੇਸ਼ਨ ਕੋਲਿਆਵਾਲੀ (ਐੱਸ/ਸੀ. ਆਨ ਡੀ/ਸੀ.)	5.960 KM	0.2 Sq. inch	123
9.	66 ਕੇ ਵੀ ਐੱਸ/ਸੀ ਲਾਈਨ ਆਨ ਡੀ/ਸੀ ਟਾਵਰ ਫਰਾਮ ਮੈਸ. ਮਿਹਿਤ ਸੋਲਰ ਪਾਵਰ ਪਲਾਂਟ ਪ੍ਰਾਈਵੇਟ ਲਿਮ., ਮਾਨਖੜਾ ਟੂ 66 ਕੇ ਵੀ ਸਬ ਸਟੇਸ਼ਨ ਸੰਘਾ।	3.280 KM	0.2 Sq. inch	68
10.	66 ਕੇ ਵੀ ਐੱਸ/ਸੀ ਲਾਈਨ ਆਨ ਡੀ/ਸੀ ਟਾਵਰ ਫਰਾਮ ਮੈਸ. ਸੋਲਏਅਰ ਪਾਵਰ ਪਲਾਂਟ ਪ੍ਰਾਈਵੇਟ ਲਿਮ., ਚਿਸਮਾਨ ਖੇੜਾ ਟੂ 66 ਕੇ ਵੀ ਸਬ ਸਟੇਸ਼ਨ ਕੋਲਰ ਖੇੜਾ।	4.525 KM	0.2 Sq. inch	94

ਟਾਵਰਜ਼, ਪੋਲਜ਼, ਵਾਇਰਜ਼, ਸਟੇਸ਼ਨ (ਖਿੱਚਾਂ) ਅਤੇ ਸਾਜ਼ ਸਾਮਾਨ ਲਗਾਉਣ ਲਈ ਜਿਹੜਾ ਕਿ ਉਕਤ ਦੱਸੇ ਅਤੇ ਦੁਰਸੰਚਾਰ ਨੋਟ ਵਰਕਸ ਲਈ ਟਰਾਂਸਮਿਸ਼ਨ ਲਾਈਨਾਂ ਲਗਾਉਣ ਲਈ ਜਿਹੜੀਆਂ ਲਾਈਨਾਂ ਦੇ ਚੰਗੀ ਤਰ੍ਹਾਂ ਕੰਮ ਕਰਨ ਲਈ ਜ਼ਰੂਰੀ ਹਨ। ਪੀ. ਐੱਸ. ਪੀ. ਸੀ. ਐੱਲ. ਦਾ ਇਰਾਦਾ ਹੈ ਕਿ ਉਹ ਆਪਣੇ ਉਨ੍ਹਾਂ ਅਧਿਕਾਰਾਂ ਦੀ ਵਰਤੋਂ ਕਰੇ, ਜਿਹੜੇ ਕਿ ਪੰਜਾਬ ਰਾਜ ਪਾਵਰ ਕਾਰਪੋਰੇਸ਼ਨ ਲਿਮਟਿਡ ਵਲੋਂ ਟੈਲੀਗ੍ਰਾਫ ਐਕਟ-1885 (XIII-ਆਫ 1885) ਅਧੀਨ ਮਿਲੇ ਹਨ। ਇਨ ਰਿਸਪੈਕਟ ਆਫ ਟੈਲੀਗ੍ਰਾਫ ਇਸਟੇਬਲਿਸ਼ਮੈਂਟ ਅਤੇ ਸਟੇਸ਼ਨ ਅਧੀਨ ਸੈਕਸ਼ਨ 164 ਆਫ ਇੰਡੀਅਨ ਇਲੈਕਟ੍ਰੀਸਿਟੀ ਐਕਟ-2003 ਲਾਗੂ ਨਹੀਂ ਹੁੰਦਾ ਅਤੇ ਉਥੇ ਪੀ. ਐੱਸ. ਪੀ. ਸੀ. ਐੱਲ. ਦੀ ਸਕੀਮ ਲਈ ਕੋਈ ਵੱਖਰਾ ਨੋਟਿਸ ਦੇਣਾ ਲੋੜੀਂਦਾ ਨਹੀਂ।

ਇਹ ਨੋਟੀਫਿਕੇਸ਼ਨ ਬਿਜਲੀ ਐਕਟ-2003 ਦੀ ਸੈਕਸ਼ਨ 164 ਦੀਆਂ ਨਵੀਆਂ ਧਾਰਾਵਾਂ ਮੁਤਾਬਿਕ ਜਾਰੀ ਕੀਤੀ ਜਾਂਦੀ ਹੈ ਅਤੇ ਪਾਵਰ ਡਿਪਾਰਟਮੈਂਟ, ਪੰਜਾਬ ਸਰਕਾਰ ਦੇ ਹੁਕਮ ਨੰ. S/O. 46/C.A 36/ 2003/ S. 164/2013 dt 19-6-2013 ਅਨੁਸਾਰ ਇੰਡੀਅਨ ਟੈਲੀਗ੍ਰਾਫ ਐਕਟ-1885 (ਸੈਟਰਲ ਐਕਟ 13 ਆਫ 1985) ਦੇ ਪਾਰਟ 3 ਅਧੀਨ ਟੈਲੀਗ੍ਰਾਫ ਅਥਾਰਟੀ ਦੀਆਂ ਪਾਵਰਜ਼ ਪੀ. ਐੱਸ. ਪੀ. ਸੀ. ਐੱਲ. ਨੂੰ vested and exercised ਕਰਨ ਦਾ ਫੈਸਲਾ ਕੀਤਾ ਜਾਂਦਾ ਹੈ। ਇਸ ਸੰਬੰਧੀ ਨੋਟਿਸ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ ਜੇ ਕਿਸੇ ਵਿਅਕਤੀ ਨੂੰ ਉਪਰੋਕਤ ਸਕੀਮ /ਟਰਾਂਸਮਿਸ਼ਨ ਲਾਈਨਾਂ ਦੇ ਕੰਮਾਂ ਸਬੰਧੀ ਕੋਈ ਇਤਰਾਜ਼ ਹੋਵੇ ਤਾਂ ਉਹ ਆਪਣੀ ਪ੍ਰਤੀ ਵੇਦਨਾ ਇਸ ਨੋਟੀਫਿਕੇਸ਼ਨ ਦੇ ਜਾਰੀ ਹੋਣ ਤੋਂ 2 ਮਹੀਨੇ ਦੇ ਅੰਦਰ ਅੰਦਰ ਦੇ ਸਕਦਾ ਹੈ। ਇਸ ਤੋਂ ਬਾਅਦ ਕੋਈ ਇਤਰਾਜ਼ ਜਾਂ ਪ੍ਰਤੀ ਵੇਦਨਾ ਸਵੀਕਾਰ ਨਹੀਂ ਕੀਤੀ ਜਾਵੇਗੀ ਅਤੇ ਸਾਰੀ ਸਕੀਮ/ ਟਰਾਂਸਮਿਸ਼ਨ ਲਾਈਨਾਂ ਦੇ ਕੰਮ ਬਿਨਾਂ ਕੋਈ ਸੋਧ ਕੀਤੇ ਜਾਂ ਸੋਧ ਕਰਕੇ ਪੀ. ਐੱਸ. ਪੀ. ਸੀ. ਐੱਲ. ਦੀ ਮਨਜ਼ੂਰੀ ਮੁਤਾਬਿਕ ਲਾਗੂ ਮੰਨੇ ਜਾਣਗੇ। ਇਸ ਸਿਲਸਿਲੇ ਵਿਚ ਲੋੜੀਂਦੇ ਆਰਜ਼ੀ ਪਲਾਨ ਜਿਨ੍ਹਾਂ ਵਿਚ ਟਰਾਂਸਮਿਸ਼ਨ ਲਾਈਨਾਂ ਦੇ ਰਸਤੇ ਵਿਖਾਏ ਗਏ ਹਨ, ਕਿਸੇ ਵੀ ਕੰਮਕਾਰ ਵਾਲੇ ਦਿਨ ਉਪ ਮੁੱਖ ਇੰਜੀਨੀਅਰ/ਟੀ. ਐੱਲ., ਹਲਕਾ ਪੀ. ਐੱਸ. ਪੀ. ਸੀ. ਐੱਲ. ਜਲੇਧਰ ਦੇ ਦਫਤਰ ਵਿਚ ਵੇਖੇ ਜਾ ਸਕਦੇ ਹਨ। ਉਪਰੋਕਤ ਸਕੀਮਾਂ ਸਬੰਧੀ ਜੇ ਕੋਈ ਇਤਰਾਜ਼ ਅਤੇ ਪ੍ਰਤੀ ਵੇਦਨਾ ਹੋਵੇ ਤਾਂ ਨਿਮਨਹਸਤਾਖਰ ਨੂੰ ਭੇਜੇ ਜਾਣ।

ਉਪਰੋਕਤ ਕੰਮ ਪੰਜਾਬ ਰਾਜ ਦੇ 66 ਕੇ ਵੀ ਟਰਾਂਸਮਿਸ਼ਨ-ਨੋਟਵਰਕ ਵਿਚ ਵਾਧਾ/ ਸਮਰੱਥਾ ਵਧਾਉਣ ਦੇ ਮੰਤਵ ਕਰਕੇ ਪਲਾਨ ਕੀਤੇ ਗਏ ਹਨ ਤਾਂ ਜੋ ਰਾਜ ਦੇ ਸਾਰੇ ਤਰ੍ਹਾਂ ਦੇ ਮੌਜੂਦਾ/ਸੰਭਾਵੀ ਬਿਜਲੀ ਖਪਤਕਾਰਾਂ ਨੂੰ ਨਿਰਵਿਘਨ ਅਤੇ ਵਧੀਆ ਬਿਜਲੀ ਸਪਲਾਈ ਦਿੱਤੀ ਜਾ ਸਕੇ। ਇਹ ਕੰਮ ਬਿਜਲੀ ਖਪਤਕਾਰਾਂ ਨੂੰ ਮਿਆਰੀ ਪਾਵਰ ਸਪਲਾਈ ਯਕੀਨੀ ਬਣਾਉਣ ਲਈ ਅਤਿਅੰਤ ਲੋੜੀਂਦੇ ਹਨ।

ਉਪ ਮੁੱਖ ਇੰਜੀਨੀਅਰ/ਟਰਾਂਸਮਿਸ਼ਨ ਲਾਈਨ (ਡ.),

ਪੀ. ਐੱਸ. ਪੀ. ਸੀ. ਐੱਲ., ਪਟਿਆਲਾ

C-471/15

PR-4465-C-7.10.15

ਮੁੱਖ ਇੰਜੀਨੀਅਰ/ਟੀ. ਐੱਸ. ਪੰਜਾਬ ਸਟੇਟ ਪਾਵਰ ਕਾਰਪੋਰੇਸ਼ਨ ਲਿਮਟਿਡ.

ਬੀ-1, ਸ਼ਕਤੀ ਵਿਹਾਰ, ਪਟਿਆਲਾ

ਬਿਜਲੀ ਕੱਟਾਂ ਨੂੰ ਘਟਾਉਣ ਲਈ ਬਿਜਲੀ ਦੀ ਬੱਚਤ ਕਰੋ।

ਪੀ. ਐੱਸ. ਪੀ. ਸੀ. ਐੱਲ. ਵੈਬਸਾਈਟ [www.pspcl.in](http://www.pspcl.in) ਤੋਂ ਆਨਲਾਈਨ 24x7 ਬਿਜਲੀ ਬਿੱਲ ਅਦਾ ਕਰੋ।



## ACME Global Environment Health & Safety Policy

ACME values the surroundings as they are important resources and is committed to minimize adverse Environment Health & Safety impacts of their business during the entire life cycle of the project, and dedicate them further to –

- Comply with all applicable Environment Health & Safety legislations and all other requirements of interested parties.
- Adopt measures to prevent pollution, injuries & ill health.
- Ongoing improvement in processes and continual improvement in Environment Health & Safety performance.
- Adopting measures to minimize accidents and optimal utilization of resources, in particular groundwater and adopting waste management practices.
- Educating, motivating and involving all our suppliers and business associates to adopt similar approaches towards environment protection and safety realization in their products, activities and services.
- This Environment Health & Safety policy should be widely communicated to all persons working for or on behalf of ACME.
- The policy statement shall have to be communicated to all employees and sub-contractors of the plant with the intent that they are made aware of their individual obligations. It should be ensured that this is understood and implemented by all concerned.
- This policy shall be available to interested parties and public and shall be reviewed periodically to ensure that they remain relevant and appropriate to company.

**Managing Director**